



Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · www.gpwaterlab.com

Mail To:

Rogue River School District 35

Attn: Larry Plew

P.O. Box 1045

Rogue River, OR 97537

Date: July 13, 2016

Address of Source: Rogue River High School

Sample ID #: 21602322

Project Name: RRSD 35 HS

Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark
Senior Chemist

Sample Information

Sample ID:	21602322	Collectors Name:	Larry Plew
Address of Source:	Rogue River High School	Sample Point:	N/A
Project Name:	RRSD 35 HS	Source:	Dist-A
Received Date:	07/07/2016	Treatment System:	None

Results of Chemical Analysis

Sample Notes:		RRHS Custodian Sink		Collection Date:		07/06/16 6:58 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0062	mg/L	1.3	07/08/16 2:17 pm	JNS	AA	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AF	A
Sample Notes:		RRHS Kitchen Hand Sink		Collection Date:		07/06/16 6:59 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.0177	mg/L	1.3	07/08/16 2:17 pm	JNS	AB	A
Lead	SM 3113 B	0.01	0.0185	mg/L	0.015	07/08/16 9:04 am	JNS	AG	A
Sample Notes:		RRHS Main Drinking Fountain		Collection Date:		07/06/16 7:00 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.1147	mg/L	1.3	07/08/16 2:17 pm	JNS	AC	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AH	A
Sample Notes:		RRHS Staff Lounge Sink		Collection Date:		07/06/16 7:10 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	ND	mg/L	1.3	07/08/16 2:17 pm	JNS	AD	A
Lead	SM 3113 B	0.01	0.0131	mg/L	0.015	07/08/16 9:04 am	JNS	AI	A
Sample Notes:		RRHS Rm 38 1st Sink on L		Collection Date:		07/06/16 7:30 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Copper	EPA 200.7	0.006	0.1895	mg/L	1.3	07/08/16 2:17 pm	JNS	AE	A
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/08/16 9:04 am	JNS	AJ	A

DEFINITIONS AND DATA FLAGS

A Analysis is covered under ORELAP scope of Accreditation
 AA Analysis is covered under ISO scope of Accreditation
 C Sample did not meet acceptance criteria
 H Analysis performed outside method hold time
 ID Subsample identifier for each Sample number
 M Matrix Spike recovery is out of control limits due to matrix interference
 The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

E Estimated Value
 LOQ Reporting Limit
 N/A Not Applicable
 ND None Detected
 S Sample Outsourced

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss



Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street · Grants Pass, OR 97526 · 541-476-0733 · www.gpwaterlab.com

Mail To:

Rogue River School District 35

Attn: Larry Plew

P.O. Box 1045

Rogue River, OR 97537

Date:

July 20, 2016

Address of Source:

N/A

Sample ID #:

21602506

Project Name:

Rogue River High School

Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark
Senior Chemist

Sample Information

Sample ID:	21602506	Collectors Name:	Larry Plew
Address of Source:	N/A	Sample Point:	N/A
Project Name:	Rogue River High School	Source:	Dist-A
Received Date:	07/19/2016	Treatment System:	None

Results of Chemical Analysis

Sample Notes:		Kitchen Hand Sink		Collection Date:		07/19/16 6:42 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	ND	mg/L	0.015	07/20/16 9:04 am	JNS	AC	A
Sample Notes:		Teacher's Staff Lounge		Collection Date:		07/19/16 7:00 AM			
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	0.01	0.0104	mg/L	0.015	07/20/16 9:04 am	JNS	AA	A

DEFINITIONS AND DATA FLAGS

- A Analysis is covered under ORELAP scope of Accreditation
- AA Analysis is covered under ISO scope of Accreditation
- C Sample did not meet acceptance criteria
- H Analysis performed outside method hold time
- ID Subsample identifier for each Sample number
- M Matrix Spike recovery is out of control limits due to matrix interference
The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

- E Estimated Value
- LOQ Reporting Limit
- N/A Not Applicable
- ND None Detected
- S Sample Outsourced

Results Color Key
White - No EPA Limit
Low Risk within EPA Limit
Medium Risk
High Risk Exceeds EPA Limit
Call the Lab to Discuss



Grants Pass Water Lab

"Fast & Reliable Water Testing Since 1978"

964 SE M Street • Grants Pass, OR 97526 • 541-476-0733 • www.gpwaterlab.com • ORELAP# OR100033

Mail To:

Rogue River School District 35

Attn: Larry Plew
P.O. Box 1045
Rogue River, OR 97537

Date: January 06, 2017
Address of Source: N/A
Sample ID #: 21700005
Project Name: Rogue River School District
1898 E Evans Ck Rd

Analysis Report

The following results pertain only to the samples submitted, and are for the sole and exclusive use of the above named client.

This report shall not be reproduced, except in full, without written approval of the laboratory.

The following accredited results meet all requirements of ISO/IEC17025:2005 unless otherwise noted by data flag indicators or comments.

The color coded key is only a guide for interpreting results. All evaluations should be compared to the limitations set by the EPA and/or your primary care physician.

Please do not hesitate to call to discuss results or ask any questions. We are at your service!

Sincerely,

Jessica Stark
Senior Chemist

Sample Information

Sample ID: **21700005** Collectors Name: Larry Plew
 Address of Source: N/A Sample Point:
 Project Name: Rogue River School District Source: *Well City*
 Received Date: 01/03/2017 Treatment System: None

Results of Chemical Analysis

Sample Notes:		1) Kitchen Eye Wash Sink		Collection Date:	01/03/17 6:30 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AA	A	
Sample Notes:		2) Kitchen Hand Wash Sink		Collection Date:	01/03/17 6:31 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AB	A	
Sample Notes:		3) Kitchen Left Side Sink		Collection Date:	01/03/17 6:32 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0241	mg/L	0.015	01/05/17 9:52 am	JNS	AC	A	
Sample Notes:		4) Kitchen Right Side Sink		Collection Date:	01/03/17 6:33 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0216	mg/L	0.015	01/05/17 9:52 am	JNS	AD	A	
Sample Notes:		5) Custodian Sink		Collection Date:	01/03/17 6:34 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AE	A	
Sample Notes:		6) Canteen Area Sink		Collection Date:	01/03/17 6:35 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AF	A	
Sample Notes:		7) Girls Locker Room Right Sink		Collection Date:	01/03/17 6:36 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AG	A	
Sample Notes:		8) Girls Locker Room Left Sink		Collection Date:	01/03/17 6:38 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AH	A	
Sample Notes:		9) Boys Locker Room Right Sink		Collection Date:	01/03/17 6:39 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AI	A	
Sample Notes:		10) Boys Locker Room Left Sink		Collection Date:	01/03/17 6:40 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AJ	A	
Sample Notes:		11) Boys Locker Room Drinking Fountain		Collection Date:	01/03/17 6:41 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AK	A	
Sample Notes:		12) Team Locker Room Right Sink		Collection Date:	01/03/17 6:42 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AL	A	
Sample Notes:		13) Team Locker Room Left Sink		Collection Date:	01/03/17 6:43 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AM	A	

Results of Chemical Analysis

Sample Notes:	14) Main Gym Drinking Fountain			Collection Date:	01/03/17 6:48 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AN	A	
Sample Notes:	15) Staff Lounge Sink			Collection Date:	01/03/17 6:52 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AO	A	
Sample Notes:	16) Back Office Sink			Collection Date:	01/03/17 6:53 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AP	A	
Sample Notes:	17) Main Office Men's Bathroom			Collection Date:	01/03/17 7:00 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AQ	A	
Sample Notes:	18) Main Office Women's Bathroom			Collection Date:	01/03/17 7:01 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AR	A	
Sample Notes:	19) Room 23 #1 Sink			Collection Date:	01/03/17 7:08 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/05/17 9:52 am	JNS	AS	A	
Sample Notes:	20) Room 23 #2 Sink			Collection Date:	01/03/17 7:09 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	AT	A	
Sample Notes:	21) Room 23 #3 Sink			Collection Date:	01/03/17 7:11 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	AU	A	
Sample Notes:	22) Room 32 #1 Sink			Collection Date:	01/03/17 7:33 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	AV	A	
Sample Notes:	23) Room 32 #2 Sink			Collection Date:	01/03/17 7:34 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	AW	A	
Sample Notes:	24) Room 32 #3 Sink			Collection Date:	01/03/17 7:35 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	AX	A	
Sample Notes:	25) Chemical Room #1 Sink			Collection Date:	01/03/17 7:42 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0205	mg/L	0.015	01/06/17 8:12 am	JNS	AY	A	
Sample Notes:	26) Chemical Room #2 Sink			Collection Date:	01/03/17 7:43 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0270	mg/L	0.015	01/06/17 8:12 am	JNS	AZ	A	
Sample Notes:	27) Room 33 #1 Sink			Collection Date:	01/03/17 7:55 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	BA	A	
Sample Notes:	28) Room 33 #2 Sink			Collection Date:	01/03/17 7:56 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	BB	A	
Sample Notes:	29) Room 33 #3 Sink			Collection Date:	01/03/17 7:58 AM					
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	

Results of Chemical Analysis

Sample Notes:		29) Room 33 #3 Sink			Collection Date:	01/03/17 7:58 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0285	mg/L	0.015	01/06/17 8:12 am	JNS	BC	A	
Sample Notes:		30) Room 33 #4 Sink			Collection Date:	01/03/17 8:00 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0239	mg/L	0.015	01/06/17 8:12 am	JNS	BD	A	
Sample Notes:		31) Art Room #1 Sink			Collection Date:	01/03/17 8:15 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0176	mg/L	0.015	01/06/17 8:12 am	JNS	BE	A	
Sample Notes:		32) Art Room #2 Sink			Collection Date:	01/03/17 8:18 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	0.0122	mg/L	0.015	01/06/17 8:12 am	JNS	BF	A	
Sample Notes:		33) Art Room #3 Sink			Collection Date:	01/03/17 8:19 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	BG	A	
Sample Notes:		34) Art Room #4 Sink			Collection Date:	01/03/17 8:21 AM				
Contaminate	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags	
Lead	SM 3113 B	0.01	ND	mg/L	0.015	01/06/17 8:12 am	JNS	BH	A	

DEFINITIONS AND DATA FLAGS

- A Analysis is covered under ORELAP scope of Accreditation
- AA Analysis is covered under ISO scope of Accreditation
- C Sample did not meet acceptance criteria
- H Analysis performed outside method hold time
- ID Subsample identifier for each Sample number
- M Matrix Spike recovery is out of control limits due to matrix interference
The LCS was in acceptance limits showing the analysis is in control and the data is acceptable

- E Estimated Value
- LOQ Reporting Limit
- N/A Not Applicable
- ND None Detected
- S Sample Outsourced

Results Color Key

White - No EPA Limit

Low Risk
within EPA Limit

Medium Risk

High Risk
Exceeds EPA Limit

Call the Lab to Discuss