

# Sample Information

Sample ID:	22100867	Collectors Name:	Scott Hanson
Address of Source:	518 E. Main St.	Sample Point:	N/A
Project Name:	South Valley Academy	Source:	City
Received Date:	03/10/2021	Treatment System:	None

## Results of Chemical Analysis

Sample Notes:	Kitchenette	Collection Date:	03/10/21 6:30 AM		Fixture ID:	K			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AA	
Sample Notes:	Mens Bathroom Sink	Collection Date:	03/10/21 6:35 AM		Fixture ID:	MBI			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AB	
Sample Notes:	Womens Bathroom Sink 1	Collection Date:	03/10/21 6:40 AM		Fixture ID:	WB2A			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AC	
Sample Notes:	Womens Bathroom Sink 2	Collection Date:	03/10/21 6:45 AM		Fixture ID:	WB2B			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AD	
Sample Notes:	Staff Bathroom Sink	Collection Date:	03/10/21 6:50 AM		Fixture ID:	SB			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AE	
Sample Notes:	ADA Bathroom Sink	Collection Date:	03/10/21 6:55 AM		Fixture ID:	ADAB			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AF	
Sample Notes:	East Room Sink	Collection Date:	03/10/21 7:00 AM		Fixture ID:	ES			
Contaminant	Method	LOQ	RESULTS	Units	EPA Limit	Date Analyzed	Analyst	ID	Data Flags
Lead	SM 3113 B	2.25	ND	ppb	15.0	03/11/21 7:59 am	JNS	AG	

**DEFINITIONS AND DATA FLAGS**

<p>A Analysis is covered under ORELAP scope of Accreditation</p> <p>AA Analysis is covered under ISO scope of Accreditation</p> <p>C Sample did not meet acceptance criteria</p> <p>H Analysis performed outside method hold time</p> <p>ID Subsample identifier for each Sample number</p> <p>M Matrix Spike recovery is out of control limits due to matrix interference The LCS was in acceptance limits showing the analysis is in control and the data is acceptable</p>	<p>E Estimated Value</p> <p>LOQ Reporting Limit</p> <p>N/A Not Applicable</p> <p>ND None Detected</p> <p>S Sample Outsourced</p>
---	--

Results Color Key	
White - No EPA Limit	
Low Risk within EPA Limit	
Medium Risk	
High Risk Exceeds EPA Limit	
Call the Lab to Discuss	